



Corrigendum No.1 to This Office e NIT No 12 of 2018-19 Dated:08-12-2018 for Design, Supply at Site, Installation Testing and Commissioning of V.T Pumps Electric Motor Driven, along with Allied Electromechanical Accessories And Auxiliaries At Tral Lift Irrigation Scheme Stage 3rd.

Please read Annexure "C" S. No 6 i.e Number of stages as, 'not more than 4 stages' instead of "not more than 3 stages".

Further in Annexure "C" S.No.20 the minimum thickness of delivery manifold including, deliveries junctions and headers etc shall be at least 12mm.

The specifications/NIT requirements are to be quoted /confirmed accordingly.

Rest of terms and conditions laid in the e NIT shall remain the same.

No : MICD/ 3933-36
Division,
Date: 21-12-2018

Sd/-
(*Er. Raja Yousuf Ali Khan*)
Executive Engineer,
Mech. Irri. Const.
Srinagar.

Copy to:-

1. Chief Engineer, Kashmir Irrigation & Flood Control Department, Srinagar for favour information please.
2. Superintending Engineer, Mechanical Circle, Irrigation and Flood Control Department, Srinagar for favour of information.
3. Assistant Executive Engineer, Mechanical New Lift Sub Division Srinagar for information.
4. Admin departmental website (tenders@ifckashmir.com) for necessary action.
5. Notice Board.