



## **Corrigendum No 1**

Corrigendum No. 01 Dated 10/08/2017 for e-NIT No. 09 of 2017-18 Dated 19/07/2017 for “***Design, Supply At Site, Installation Testing And Commissioning of V.T Motor Driven Pumps, Allied Electromechanical Equipments And Auxiliaries At Tral Lift Irrigation Scheme Stage 3<sup>rd</sup>***”.

The pump house elevation is given as below:

1. SUMP BED LEVEL (Assumed) =0.00M
2. MINIMUM WATER LEVEL =3.00M
3. MACHINE FLOOR LEVEL =6.750M
4. C/L OF DISCHARGE ELBOW =5.350M
5. GANTRY LEVEL IN PUMP HOUSE =14.750M

Rest of the details given in the tender document shall remain unchanged.

*Sd/-*  
*Executive Engineer,*  
*Mech. Irri. Const. Division,*  
*Srinagar.*

**No : MICD/2569-72**

**Date: 10-08-2017**

### **Copy to the:-**

1. Chief Engineer, Kashmir Irrigation & Flood Control Department, Srinagar for favour of information.
2. Superintending Engineer, Mechanical Circle, Irrigation and Flood Control Department, Srinagar for information.
3. The Joint Director, Information Department, Srinagar information. He is requested to get the said Corrigendum published in the two leading dailies.
4. Assistant Executive Engineer, Mechanical New lift Sub Division, Srinagar for information. This has reference to his letter No: NLSD/597 Dated: 31-07-2017.
5. Notice Board.