



Corrigendum No 3

Corrigendum No. 03 Dated 22/08/2017 for e-NIT No. 09 of 2017-18 Dated 19/07/2017 for “**Design, Supply At Site, Installation Testing And Commissioning of Motor Driven V.T Pumps, Allied Electromechanical Equipments And Auxiliaries At Tral Lift Irrigation Scheme Stage 3rd ”.**

Clause of SBD	Corrigendum/To be read as
12.01.05.01 One set, 120 volts, lead acid battery comprising 10, high performance, closed top cells (each 12 volts). Corrigendum no:02 Dated:16-08-2017 Each battery of the bank to be as per design of the OEM/Industry standard and specifications to be specified in Cover 1 st by the bidder	One set,120 Volts, comprising of 60 Number Sealed Maintenance Free Valve Regulated lead acid batteries (SMFVRL) and specifications to be specified/quoted in Cover 1 st cover 2 nd accordingly by the bidder.

Rest of the details given in the tender document shall remain unchanged.

Sd/-

No : MICD/ 2909-12
Date: 22-08-2017

*Executive Engineer,
Mech. Irri. Const. Division,
Srinagar.*

Copy to the:-

1. Chief Engineer, Kashmir Irrigation & Flood Control Department, Srinagar for favour of information.
2. Superintending Engineer, Mechanical Circle, Irrigation and Flood Control Department, Srinagar for information.
3. The Joint Director, Information Department, Srinagar information. He is requested to get the said Corrigendum published in the two leading dailies.
4. Assistant Executive Engineer, Mechanical New lift Sub Division, Srinagar for information.