



Corrigendum No 4

Corrigendum No. 04 Dated 23/08/2017 for e-NIT No. 09 of 2017-18 Dated 19/07/2017 for “**Design, Supply At Site, Installation Testing And Commissioning of Motor Driven V.T Pumps, Allied Electromechanical Equipments And Auxiliaries At Tral Lift Irrigation Scheme Stage 3rd ”**”.

Clause of SBD	Corrigendum/To be read as
<p>12.01.05.01 One set, 120 volts, lead acid battery comprising 10, high performance, closed top cells (each 12 volts).</p> <p>Corrigendum no:02 Dated:16-08-2017 Each battery of the bank to be as per design of the OEM/Industry standard and specifications to be specified in Cover 1st by the bidder</p> <p>Corrigendum no:03 Dated:22-08-2017 One set, 120 Volts, comprising of 60 Number Sealed Maintenance Free Valve Regulated lead acid batteries (SMFVRL) and specifications to be specified/quoted in Cover 1st cover 2nd accordingly by the bidder.</p>	<p>One set, 110 Volts, comprising of 55 Number 2V each, Sealed Maintenance Free Valve Regulated lead acid batteries (SMF VRLA) and specifications to be specified / quoted in Cover 1st cover 2nd accordingly by the bidder.</p>

Rest of the details given in the tender document shall remain unchanged.

Sd/-

No : MICD/ 2916-19

Date: 23-08-2017

*Executive Engineer,
Mech. Irri. Const. Division,
Srinagar.*

Copy to the:-

1. Chief Engineer, Kashmir Irrigation & Flood Control Department, Srinagar for favour of information.
2. Superintending Engineer, Mechanical Circle, Irrigation and Flood Control Department, Srinagar for information.
3. The Joint Director, Information Department, Srinagar information. He is requested to get the said Corrigendum published in the two leading dailies.
4. Assistant Executive Engineer, Mechanical New lift Sub Division, Srinagar for information.