



GOVERNMENT OF JAMMU AND KASHMIR  
**OFFICE OF THE EXECUTIVE ENGINEER, MECHANICAL IRRIGATION DIVISION SRINAGAR**  
**Near J&K Bank (Zaldagar)**

Telefax No. 0194-2503195 e.mail Id: [xenmidsrinagar@gmail.com](mailto:xenmidsrinagar@gmail.com)

**Sub:- “Supply, Installation , Testing and Commissioning of 400 Amp L.T Control Panel for *Lift Irrigation Scheme* Zazna “B” Ganderbal”**

**Ref:- This office NIT No. 37 of 2017-18, Dated:04-01-2018, issued vide No. 4946-52, Dated: 04-01-2018.**

# CORRIGENDUM

Please read DN3-400N, 320-400Amp, 50KA MCCB “L&T” make instead of C-power SL 95351, 400Amp.in the incoming feeder and DN-250C,200-250MCCB, 3 pole 50KA MCCB “L&T” make instead of DN-3-400N,320-400Amp. In the outgoing feeder in the Annexure “A” of technical specifications of above referred NIT.

**No. MIDS/Ts/5048-55**  
**Dated:- 09-01-2018**

**Sd/-**  
Executive Engineer,  
Mechanical Irrigation Division,  
Srinagar

**Copy to the:-**

1. Chief Engineer, Kmr. I&FC Department Srinagar for information.
2. Superintending Engineer, Mechanical Circle, I & F.C Department Srinagar for information please.
3. Executive Engineer, I&F.C Division, Ganderbal for information please.
4. Joint Director Information Jammu & Kashmir Govt. Srinagar for favour of publication of this Gist of Tender Notice in any two local leading Dailies of the valley well before the Last Date of Sale of Tender Document.
5. Assistant Executive Engineer, MISD **Ganderbal** for information.
- 6-8. Technical Officer /A.A.O/ Head Assistant Divisional Office for information.

**\* In-charge Official website Kmr. I&FC Department Srinagar through e-mail for hoisting of the NIT on the official website i.e [www.ifckashmir.com](http://www.ifckashmir.com).**

- Notice Board
- Office file.